

TENDER #91137025 UPDATES

Dear valued suppliers,

Reference to the clarification session held on the 1st of March 2020, kindly find below the necessary UPDATES:

- In addition to the technical specifications, the bidder is required to add the following:
 - Supply, install and test a mechanical flow meter to measure the amount of water produced with the same diameter as the delivery pipeline.

- Question:

Is there a specific amount of water that we must stick to daily/monthly /yearly?

 - Answer:

NO, the specification of the required pump has been determined in the Tender Documents and we want the bidders to give us by calculation the maximum amount of water that can be taken from this pump at this site throughout the year. But if the required quantity of water is determined annually, the pump specifications may change, and subsequently the amount of energy required from the panels will change (and the space for installation the panels)

- The field visit will be on the 16th of March 2020 and in coordination with:
 - Eng. Mohamed Ali
Mobile number: 01272212290